

City of St. Johns

2007 Water Quality Report

Microbial Contaminants	MCL	MCLG	Number of Detections	Violation Y/N	Typical Source of Contaminant
Total Coliform Bacteria	0 Positive monthly sample	0			Naturally present in the environment
Fecal Coliform & E. Coli	Routine & repeat sample total coliform positive, and one is also fecal or E. coli positive	0			Human & animal fecal waste

For more information about your water, or the contents of this report, contact Albert Sodman 224-8944 ext. 234 between 8:00 am and 4:00 pm Monday-Friday or visit the U.S. Environmental Protection Agency at www.epa.gov/safewater/.

Regulated Contaminant		MCLG	Our Water	Sample Date	Violation Yes/No
Arsenic (ppb)	10	0	Not Detected	12/18/06	No
Barium (ppb)	2	2	0.18	05/09/00	No
Fluoride (ppm)	4	4	0.41	08/06/07	No
Radioactive Contaminant					
Alpha emitters (pCi/L)	15	0	6.07	11/10/03	No
Unregulated Contaminant					
Sodium (ppm)	Not Regulated		39	08/06/07	No
Sulfate (ppm)	Not Regulated		40	08/06/07	No
Bromoform (ppb)	Not Regulated		Not Detected	08/06/07	No
Chloroform (ppb)	Not Regulated		Not Detected	08/06/07	No
Dichlorobromomethane (ppb)	Not Regulated		0.2	08/24/07	No
Chlorodibromomethane (ppb)	Not Regulated		Not Detected	08/06/07	No
Contaminant Subject to AL	Action Level		90% ≤ This Level		# Above AL
Lead (ppb)	15		0.10	08/23/06	0
Copper (ppb)	1.3		0.44	08/23/06	0